




/
jtpark@kier.re.kr



[1]

97%

가

[2]

가

5
10

가

가


[3]

가


(Heat Pump)

[1]


가



[2]



[3]



[4]

가

[4]

0.5

COP

가

가

가

가

가

가

COP

가

가

()

(+ 가


)

가


[5]

[6]

COP




()



()

[5]

COP



[1]

	<ul style="list-style-type: none"> 가 가 가
	<ul style="list-style-type: none"> 가 가 가
	<ul style="list-style-type: none"> 가 가 가
	<ul style="list-style-type: none"> 가 가 가

()

[6]

가


가

가

[1]

가

(1)



[7]

(COP)가 가

가

20%

가


8]

가


(2)

[7]

가




[8]



[9]

3
20%
[9]



[11]

10% 1

가 [11] 가


95% [10]

가 가

COP

가
가

$$\text{COP} = \frac{\text{(Mcal/h)}}{\text{(kW)}} = \text{COP} \div 0.86(\text{Mcal/kW})$$




[10]

가 가가 2
가 가

(2)

[14]



[14]

가

60%

가

3.2

가

가

7

가

(1)

Trondheim

Royal Garden

Hotel

가

2

900kW,

600kW

/

가

/

40RT

R-22

가 20 25

7

3.2

1

3.5

2,200MWh

가

2

가 8 12

50

4.0

4.5

<http://caddet-ee.org>

(

30%

Kristiansand

Skeiebygget

1987 (75%) (25%)
9,440m²

NOK 678,000
NOK 300,000(USD 45,000),

3.5 (http:
//caddet-ee.org)
Stokmarknes 15,000m²

400kW , 2.5GWh/y 88%
8m 0

~ 14 가 55 ~ 65

1,235,000kWh/y , COP 2.6
1.7 NOK/kWh,

7 , 9 (http://caddet-ee.org)


1982 가 Favus-
grden 5,500m² 5 (北九州)

120kW ,
550,000kWh 94가
35 ~ 45

COP 3.5fh 36
147,000kWh/y

368,000kWh/y ,
480,000NOK, 0.26NOK/kWh

3.5 (http://caddet-ee.org)



[15] 堀川 [15]

[2] 5

5 ~ 12
5 4.7, 8

5.94, 12 5.3
242m³/h

2,490m³/
1000m³ 600m³

[2] 堀川


(2) NEDO(
)
14,000m² COP가 6.4,
COP 5.0
1994 1 Horikawa

	7.0	45.1
	32.1	10.0
	7.1	6.2
	1,201kW	1,345kW
	HCFC-22/HCFC-142b (79/21)	

[3]

		가	
1.	450RT	1,400Mcal/h	
2.	300RT	950Mcal/h	
3. 가	400RT × 2	1,300Mcal/h	
4.	960RT		
5.	(1,080m ³)	250RT	
6.	(2,160m ³)	500RT	1,512Mcal/h
7.	(400m ³)	550RT	
	3,810RT	6,462Mcal/h	

()



[16]

[3]

[16]

가 7%

(NOx : 6.0%, SOx : 9.0%, CO₂ : 7.0%) 가

, 가

2가

38%

450RT, 1,400

(3)

Mcal/h

55

[4]

가

6,120m³/day ~ 14,688m³/day

[4]

No			/ [Mcal/h]	
1	等等力	川崎市	300/300	1982
2	樂合	東京都	530/498	1986
3	湯鳥	東京都	344/126	1988
4	中部	横浜市	60/60	1988
5	定山溪	札幌市	71/111	1988
6	金澤	横浜市	362/420	1988
7	各城	名古屋市	330.2/360	1988
8	木場	東京都	240/240	1989
9	芦屋	芦屋	116/135	1989
10	新河岸	東京都	604.8/580	1990
11	今池	大阪府	272/370	1990
12	幕場 가	東京電力	34,776/35,290	1991
13	森森崎	東京都	304/292	1991
14	露橋	名古屋市	27/34	1991

[5]

	<ul style="list-style-type: none"> • • • • <p>가(가) 가</p> <p>(流況)</p> <p>가 가 3 가</p> <p>가, 가 가</p>
	<ul style="list-style-type: none"> • • <p>가</p> <p>가</p>
	<ul style="list-style-type: none"> • • • <p>가 가 가</p> <p>가, 가</p> <p>가 1</p> <p>7</p> <p>7</p>

가

[5]

가

가

가 (流水占用)

(: 042-860-3175)